

Entrance Monitor Wiring Instructions

Example 1



Example 2



Gas detection controller, PLC or power supply

Next entrance monitor or sensor

Instructions

1. Run Cable from power source (PLC, controller or power supply) into "TO CONTROLLER" terminal.
2. Run cable from "TO SENSOR" terminal to the next entrance monitor.
3. Repeat step 2 until you have fed through every entrance monitor in sequence.
4. On the last entrance monitor, finish by running cable to the sensor.